



KENYA URBAN ROADS AUTHORITY
Efficient and safe urban roads

IKM PLACE, Bishops Road. Tel: 254-020-8013844
Email: info@kura.go.ke Web: www.kura.go.ke
P.O. Box 41727-00100, GPO, NAIROBI

Ref: KURA/F&A/PROC/3/ (98)

Date: 11th April, 2019

TO ALL BIDDERS

Dear Bidder,

RE: CONSTRUCTION TO BITUMEN STANDARDS OF:

1. RHINO PARK ACCESS ROADS;
TENDER NO: KURA/HQ/DEV/213/2018-2019
2. GITHURAI-KIMBO ROADS PHASE III;
TENDER NO: KURA/HQ/DEV/214/2018-2019
3. LUCKY SUMMET-GITWAMBA-KASARANI LINK ROAD;
TENDER NO: KURA/HQ/DEV/215/2018-2019
4. HUNTERS-GITHURAI LINK ROAD;
TENDER NO: KURA/HQ/DEV/216/2018-2019

TENDER CLARIFICATIONS

RHINO PARK ACCESS ROADS: TENDER NO: KURA/HQ/DEV/213/2018-2019		
Bill Item No.	Clarification	Response
12.01	Under bill no. 12.01, the Natural gravel material is for base repair areas while the cross-section provides the same for subbase.	Bill no. 12.01 includes gravel to be used both as neat base on the proposed walkways/footpaths as well as cement improved sub-base on the carriageway.
13.01	Under bill No. 13, the thickness for GCS is provided as 225mm while the extent of contract and cross-section provides for 150mm.	The thickness for cement improved GCS shall be 150mm as indicated in the special specifications under Clause 102 and the cross-section drawings.

14.02	Under bill No. 14.02, mixing has been provided for the subbase only while ignoring the Stabilized GCS base layer as provided for in the cross-section and extent of contract.	The quantities provided for in Bill no. 14.02 are for mixing both the cement improved gravel subbase as well as GCS base on the carriageway.
14.03	Under Bill No. 14.03, curing has been provided for subbase only while ignoring the treated GCS base layer as provided in the cross-section and extent of contract.	The quantities provided for in Bill no. 14.03 are for curing and protection of both the cement improved gravel subbase as well as GCS base on the carriageway.
15.01	Please note under Bill No. 15.01 there is a provision for MC 70 whereas in Bill No. 15.02 there is a provision for MC 30 which contradicts the extent of contract for pavement construction which provide for improved GCS on carriageway and footpaths. (Refer page 129). Please clarify the provision of MC 30 in the bills of quantities?	MC 70 provided under Bill No. 15.01 shall be used as prime coat on the Cement improved GCS base while MC 30 provided under Bill no 15.02 shall be used as prime coat on the neat gravel base for the footpaths.
TENDER NO: KURA/HQ/DEV/213/214/215/216/2018-2019		
General	Please clarify in the clause 12 (Regulation of foreign Contractors) from the revised regulations (Rev 2017) from National Construction Authority, whether Sub Clause (2) and 3 (d) are applicable in the above mentioned tenders.	This clause is applicable to registration of foreign contractors by National Construction Authority and therefore, foreign firms or contractors duly registered by the National Construction Authority under the respective category will be deemed to have met the criteria as stipulated.

Please note that the opening date for the bids has been extended by seven (7No.) days to 23rd April, 2019. The opening time and venue remains as indicated in the tender notice.

Yours faithfully,

Loice Mburu

FOR: DIRECTOR GENERAL